



100 John West Way
Aurora, Ontario
L4G 6J1
(905) 727-3123
aurora.ca

Town of Aurora
Memorandum
Corporate Services

Re: Site Plan Application SP-2023-09 (Submission #1) 61 Allaura Boulevard

To: Accessibility Advisory Committee

From: Gregory Peri, Accessibility Advisor

Date: September 6, 2023

Recommendation

1. That the memorandum regarding Site Plan Application SP-2023-09 (Submission #1) 61 Allaura Boulevard be received; and
2. That the Accessibility Advisory Committee comments regarding Site Plan Application SP-2023-09 (Submission #1) be received and referred to staff for consideration and further action as appropriate.

Background

The following comments have been submitted on August 18, 2023 and are conditions that must be met:

- Washroom on main level that is served by the barrier-free path of travel and available to the public to be a universal washroom.
- Installation of proper tactile indicators at the proposed staircases.
- Automatic door openers for all public access locations, including proper timed door delays.

The following comments are considerations:

- Consideration for emergency evacuation chairs to be provided at all staircase locations.
- Consideration for all customer services counters to have an allocated accessibility spot and induction loop.

Attachments

SP-2023-09 Site Plans