



100 John West Way  
Aurora, Ontario  
L4G 6J1  
(905) 727-3123  
aurora.ca

Town of Aurora  
**Memorandum**  
Corporate Services

---

**Re:** Site Plan Application SP-2023-10 (Submission #1) 55 Eric T Smith Way

**To:** Accessibility Advisory Committee

**From:** Gregory Peri, Accessibility Advisor

**Date:** September 6, 2023

---

## Recommendation

1. That the memorandum regarding Site Plan Application SP-2023-10 (Submission #1) 55 Eric T Smith Way be received; and
2. That the Accessibility Advisory Committee comments regarding Site Plan Application SP-2023-10 (Submission #1) be received and referred to staff for consideration and further action as appropriate.

## Background

The following comments have been submitted on August 11, 2023 and are conditions that must be met:

- If washroom proposed, ensure it's on the main level that is served by the barrier-free path of travel and available to the public to be a universal washroom.
- Installation of proper tactile indicators at the proposed staircases.
- Automatic door openers for all public access locations, including proper timed door delays.
- The exterior path must have a minimum clear width of 1,500 mm.

The following comments are considerations:

- Spreading out the barrier-free parking spaces to ensure shortest possible accessible route to the barrier-free entrances.
- 2 spots by Office 3 & 4
- 2 spots by Unit 8 & 9
- 2 spots by Unit 14 or 15

## **Attachments**

SP-2023-10 Site Plans