



100 John West Way  
Aurora, Ontario  
L4G 6J1  
(905) 727-3123  
aurora.ca

Town of Aurora  
**Memorandum**  
Corporate Services

---

**Re:** Accessibility Advisory Committee (AAC) Input and Comments for Site Plan Application SP-2019-01 (Submission #3)

**To:** Accessibility Advisory Committee

**From:** Mateusz Zawada, Accessibility Advisor

**Date:** October 14, 2020

---

## Recommendation

1. That the memorandum regarding Accessibility Advisory Committee (AAC) input and comments for Site Plan Application SP-2019-01 (Submission #3) be received; and
2. That the Accessibility Advisory Committee comments regarding the site plan application be received and referred to staff for consideration.

## Background

The Accessibility Advisor has made comments on behalf of the Accessibility Advisory Committee.

The comments are as follows:

- Please note that the minimum number of barrier-free parking spaces is 3 parking spaces for the use of persons with disabilities, which meets the requirements of the AODA Design of Public Spaces O.Reg 191/11, section 80.36 (4).

Please also note that there are new Design of Public Spaces (Built Environment) Standards enacted from the Province of Ontario, under the Accessibility for Ontarians with Disabilities Act and revisions to the Ontario Building Code to help standardize and encourage barrier free access.

On behalf of the Accessibility Advisory Committee, thank you for the opportunity to comment.

## **Attachments**

Site Plan SP-2019-01