



100 John West Way  
Aurora, Ontario  
L4G 6J1  
(905) 727-3123  
aurora.ca

Town of Aurora  
**Memorandum**  
Corporate Services

---

**Re:** Site plan application OPA,2021-03, ZBA-2021-03, SP-2021-07 (Submission #2), 15296, 15306, 15314 Yonge Street

**To:** Accessibility Advisory Committee

**From:** Mateusz Zawada, Accessibility Advisor

**Date:** November 10, 2021

---

## Recommendation

1. That the memorandum regarding Site plan application OPA,2021-03, ZBA-2021-03, SP-2021-07 (Submission #2), 15296, 15306, 15314 Yonge Street be received; and
2. That the Accessibility Advisory Committee comments regarding Site plan application OPA,2021-03, ZBA-2021-03, SP-2021-07 (Submission #2) be received and referred to staff for consideration and further action as appropriate.

## Background

The Accessibility Advisor has made comments on behalf of the Accessibility Advisory Committee.

The comments are as follows:

- Recommended slopes for barrier-free parking are the following:
  - Have a maximum of 1.5% running slope for drainage;
  - Have a maximum cross slope of 1%;

Please also note that there are new Design of Public Spaces (Built Environment) Standards enacted from the Province of Ontario, under the Accessibility for Ontarians with Disabilities Act and revisions to the Ontario Building Code to help standardize and encourage barrier free access.

On behalf of the Accessibility Advisory Committee, thank you for the opportunity to comment.

## **Attachments**

OPA-2021-03