



100 John West Way
Aurora, Ontario
L4G 6J1
(905) 727-3123
aurora.ca

Town of Aurora
Memorandum
Corporate Services

Re: Accessibility Advisory Committee (AAC) input and comments for site plan application SP-2020-10 (Submission #1)

To: Accessibility Advisory Committee

From: Mateusz Zawada, Accessibility Advisor

Date: November 11, 2020

Recommendation

1. That the memorandum regarding Accessibility Advisory Committee (AAC) input and comments for site plan application SP-2020-10 (Submission #1) be received; and
2. That the Accessibility Advisory Committee comments regarding Accessibility Advisory Committee (AAC) input and comments for site plan application SP-2020-10 (Submission #1) be received and referred to staff for consideration and further action as appropriate.

Background

The Accessibility Advisor has made comments on behalf of the Accessibility Advisory Committee.

The comments are as follows:

- Automatic door openers for all public access locations, including proper timed door delays.
- Installation of proper tactile indicators at the proposed staircases in rear of building.
- In building phases for all customer services counters to have an allocated accessibility spot.
- Site plan does not indicate – The exterior path must have a minimum clear width of 1,500 mm.

Please also note that there are new Design of Public Spaces (Built Environment) Standards enacted from the Province of Ontario, under the Accessibility for Ontarians

with Disabilities Act and revisions to the Ontario Building Code to help standardize and encourage barrier free access.

On behalf of the Accessibility Advisory Committee, thank you for the opportunity to comment.

Attachments

SP-2010-10 (Submission 1)