



100 John West Way
Box 1000
Aurora, Ontario
L4G 6J1
Phone: 905-727-3123 ext. 4212
Email: mzawada@aurora.ca
www.aurora.ca

Town of Aurora
Corporate Services

Memorandum

Date: August 12, 2020
To: Brashanthe Manoharan, Planning and Development Services
From: Mateusz Zawada, Accessibility Advisor
Re: Accessibility Advisory Committee (AAC) Input and Comments for Site Plan Application SPM-2020-03 (Submission #1)

The Accessibility Advisor has made comments on behalf of the Accessibility Advisory Committee.

The comments are as follows:

- Please note that the minimum number of accessible parking spaces is 6 parking spaces for the use of persons with disabilities, which meets the requirements of the AODA Design of Public Spaces O.Reg 191/11, section 80.36 (4).

Please also note that there are new Design of Public Spaces (Built Environment) Standards enacted from the Province of Ontario, under the Accessibility for Ontarians with Disabilities Act and revisions to the Ontario Building Code to help standardize and encourage barrier free access.

On behalf of the Accessibility Advisory Committee, thank you for the opportunity to comment.

--

Mateusz Zawada
Accessibility Advisor
Town of Aurora