



100 John West Way
Aurora, Ontario
L4G 6J1
(905) 727-3123
aurora.ca

Town of Aurora
Memorandum
Corporate Services

Re: Site Plan Application SP-2023-05 (Submission #2)
27 Allaura Boulevard

To: Accessibility Advisory Committee

From: Gregory Peri, Accessibility Advisor

Date: April 10, 2024

Recommendation

1. That the memorandum regarding Site Plan Application SP-2023-05 (Submission #2) 27 Allaura Boulevard be received; and
2. That the Accessibility Advisory Committee comments regarding Site Plan Application SP-2023-05 (Submission #2) be received and referred to staff for consideration and further action as appropriate.

Background

The following comments have been submitted on March 5, 2024 and are conditions that must be met:

- Additional barrier-free parking space towards Unit B1 and B2 is highly recommended to reduce travel from existing Barrier-free spaces at B11.
 - I understand the current spaces meet minimum requirements however the additional spaces would assist and serve persons with disabilities better.
- I understand accommodations will be made on final fit-ups, which is great for access to the mezzanine level. This additional construction would be feasible at that time to install an elevator?

Attachments

1. SP-2023-05-Second - Response
2. SP-2023-05-Second - Site Plan