



100 John West Way
Aurora, Ontario
L4G 6J1
(905) 727-3123
aurora.ca

Town of Aurora
Memorandum
Corporate Services

Re: Site Plan Application SP-2024-01 (Submission #1)
7 Lacey Court

To: Accessibility Advisory Committee

From: Gregory Peri, Accessibility Advisor

Date: April 10, 2024

Recommendation

1. That the memorandum regarding Site Plan Application SP-2024-01 (Submission #1) 7 Lacey Court be received; and
2. That the Accessibility Advisory Committee comments regarding Site Plan Application SP-2024-01 (Submission #1) be received and referred to staff for consideration and further action as appropriate.

Background

The following comments have been submitted on March 26, 2024, and are recommendations made on behalf of the Accessibility Advisory Committee:

- Installation of appropriate accessible curb ramp wherever any path of travel crosses a curb.
- Accessible curb ramps shall align with the safe pedestrian crossing route across the vehicle roadway and incorporate a truncated dome detectable warning surface.
- Please note that the minimum number of accessible parking spaces is 1 parking space in the visitor area for the use of persons with disabilities.
- Ensure snow storage does not interfere with Barrier-Free visitor parking, nor path of travel.
- Consideration for offering Accessible housing for the community. Steps can be taken to lower grade to remove steps and other barriers.

Attachments

1. SP-2024-01 – Site Plan